



Ed Hassinger, District Engineer

**ADDENDUM 001
REQUEST FOR QUOTATION
SL13-010-R7 Brine Building Project**

Bidders shall acknowledge receipt of Addendum 001 (ONE) by signing and including it with original bid. The due date for receipt of this bid **does not change** by this Addendum. Accordingly, the following clarifications, additions/deletions, questions and answers are believed to be of general interest to all potential bidders. All other terms and conditions remain unchanged and in full force.

Name and Title of Signer (Print or type)	Name and Title of Department Authority Stephanie Austin Rashid Sr. General Services Technician
Bidder Signature	Department of Transportation <i>Stephanie Austin Rashid</i> <div>Authorizing Signature</div>
<div>Signature of person authorized to sign</div>	
Date Signed:	Date Signed: July 9, 2012

QUESTIONS AND ANSWERS

1. You specified that the buildings be built on P/T (Pressure Treated) floor joist. Is this correct?

Answer: Yes, pressure treated 2*6 floor joist is correct.

2. Also specified is T-111 siding. Is this required or do you need a similar type siding?

Answer: Something similar to T-111 siding would be ok.

3. The window in the back, does it need to be operable, or just for light?

Answer: The window doesn't need to open.

THIS PAGE MUST BE SIGNED AND RETURNED WITH ORIGINAL RFB.